

ORDINANCE NO. 19-33

AN ORDINANCE PERTAINING TO THE OLATHE ELECTRICAL CODE; AMENDING OLATHE MUNICIPAL CODE SECTIONS 15.14.010, 15.14.020, 15.14.040, 15.14.050, AND 15.14.060, AND REPEALING THE EXISTING SECTIONS; ALSO REPEALING SECTIONS 15.14.070, AND 15.14.080, 15.14.090.

BE IT ORDAINED BY THE GOVERNING BODY OF THE CITY OF OLATHE, KANSAS:

SECTION ONE: Section 15.14.010 of the Olathe Municipal Code is hereby amended to read as follows:

“15.14.010 Code Adopted.

NFPA 70, the National Electrical Code, ~~2011~~ 2017 Edition, published by the National Fire Protection Association, One Batterymarch Park, Quincy, Massachusetts 02169-7471 is adopted by reference and made a part of this chapter as if fully set out, save and except such parts or portions thereof as are specifically deleted, added or changed in Sections 15.14.040 through and including 15.14.120.”

SECTION TWO: Section 15.14.020 of the Olathe Municipal Code is hereby amended to read as follows:

“15.14.020 Marked Copies of Code on File.

There shall be not less than one (1) copy of the code adopted by reference in Section 15.14.010 kept on file in the office of the City Clerk, to which shall be attached a copy of the incorporating ordinance, and which shall be marked or stamped, “Official Copy as Incorporated by Ordinance No. ~~12-46~~ 19-33 with all sections or portions thereof intended to be omitted clearly marked to show any such deletion or change, and filed with the City Clerk and open to inspection and available to the public at all reasonable hours. ~~The Fire Department, Municipal Judges and all administrative departments of the City charged with the enforcement of the incorporating ordinance shall be supplied, at the cost of the City, such number of official copies of such standard ordinance similarly marked, deleted and changed as may be deemed expedient.~~”

SECTION THREE: Section 15.14.040 of the Olathe Municipal Code is hereby amended to read as follows:

“15.14.040 Section 90.4 (A) ~~Added~~ Amended – Administration.

Section 90.4 ~~(A) is hereby added to~~ of the National Electrical Code is hereby deleted, and a new Section 90.4 is added and shall read as follows:

90.4 (A) Administration. The administrative and enforcement provisions for this code shall be those provisions of Chapter 1 of the ~~2012~~ International Building Code as adopted by the City in accordance with Chapter 15.02 of the Olathe Municipal Code.

90.4.1 Title. The 2017 National Electrical Code and the deletions, changes, and additions contained in the Olathe Municipal Code, Chapter 15.14 shall be known as the Electrical Code of the City of Olathe, Kansas, hereinafter referred to as “this code” or “the Electrical Code.”

SECTION FOUR: Section 15.14.050 of the Olathe Municipal Code is hereby amended to read as follows:

“15.14.050 Subsection 210.8 (A) (2) Exceptions ~~1 and 2~~ Added – GFCI protection for garage and accessory building receptacles.

Subsection 210.8 (A) (2) Exceptions ~~1 and 2~~ are hereby added to the National Electrical Code and shall read as follows:

210.8 (A) (2) GFCI protection for garage and accessory building receptacles.

Exceptions to (A) (2):The following conditions shall not be required to have ground-fault circuit-interrupter protection:

1. ~~Receptacles that are not readily accessible such as a~~ A dedicated ceiling mounted receptacle for a garage door opener.

2. A single receptacle supplied by a dedicated branch circuit that is located and identified for specific use by a cord- and plug-connected appliance such as a refrigerator or freezer.

3. A dedicated receptacle supplying a permanently installed fire alarm or security alarm system.

4. A dedicated receptacle supplying a sump pump.”

SECTION FIVE: Section 15.14.060 of the Olathe Municipal Code is hereby amended to read as follows:

“15.14.060 Subsection 210.8 (A) (5) Exceptions ~~2 and 3~~ Added Amended – ~~GFCI protection for garage and accessory building receptacles~~ Unfinished portions or areas of the basement not intended as habitable rooms.

Subsection 210.8 (A) (5) Exceptions ~~2 and 3~~ in the National Electric Code are hereby ~~added~~ amended to ~~the National Electrical Code and shall~~ read as follows:

210.8 (A) (5) ~~GFCI protection for unfinished basement receptacles~~ Unfinished portions or areas of the basement not intended as habitable rooms.

Exceptions to (A) (5): The following conditions shall not be required to have ground-fault circuit-interrupter protection:

1. A receptacle supplying only a permanently installed fire alarm or burglar alarm system.

2. A single receptacle supplying a permanently installed sump pump.

3. A single receptacle supplied by a dedicated branch circuit that is located and identified for specific use by a cord- and plug-connected appliance such as a refrigerator or freezer.


Receptacles installed under exception to 210.8 (A) (5) shall not be considered as meeting the requirements of 210.52 (G)."

SECTION SIX: Existing sections 15.14.010, 15.14.020, 15.14.040, 15.14.050, 15.14.060, 15.14.070, 15.14.080, and 15.14.090 are hereby repealed.

SECTION SEVEN: This Ordinance shall be published as provided by law and shall take effect September 1, 2019 and be in force from and after that date.


PASSED by the Governing Body this 18th day of June, 2019.

SIGNED by the Mayor this 18th day of June, 2019.



Mayor Pro Tem

ATTEST:




City Clerk



(SEAL)

APPROVED AS TO FORM:



City Attorney

Publish one time and return one Proof of Publication to the City Clerk and one to the City Attorney.

STATE OF KANSAS
JOHNSON COUNTY, SS

Brandon Humble, being first duly sworn, deposes and says: That he is the editor of **THE GARDNER NEWS** A weekly newspaper printed in the State of Kansas, and published in and of general circulation in Johnson County, Kansas and that said newspaper is a bi-weekly published at least weekly, 52 times a year; has been published continuously and uninterruptedly in said county and state for a period of more than five years prior to the first publication of said notice; and has been admitted at the post office in Gardner, Kansas in said county as second class matter.


That the attached notice is a true copy there of and was published in the regular and entire issue of said newspaper for 1 consecutive weeks(s),

The first publication there of being made as aforesaid on 6/26/19

Publications being made on the following:

EDITOR *Brandon Humble*

SUBSCRIBED AND SWORN TO ME THIS : June 26. 2019

NOTARY PUBLIC *Brandon K. Humble*


MY COMMISSION EXPIRES 5-11-22

COST-----

ADDITIONAL COPIES-----

IN THE DISTRICT COURT OF JOHNSON, C

The within Proof Of Publication approved

Public Notice

First published in *The Gardner News* Wednesday, June 26, 2019

PUBLICATION SUMMARY OF ORDINANCE NO. 19-33, PASSED BY THE GOVERNING BODY OF THE CITY OF OLATHE, KANSAS ON THE 18th DAY OF JUNE 2019.

SUMMARY

On June 18, 2019, the Governing Body of the City of Olathe, Kansas passed Ordinance No. 19-33, which amends Chapter 15.14 of the Olathe Municipal Code, pertaining to the electrical code.

The ordinance adopts the 2017 National Electrical Code with certain amendments specific to the City of Olathe. The complete text of this ordinance may be obtained or viewed free of charge at the office of the Olathe City Clerk, Olathe City Hall, 100 East Santa Fe Street, Olathe, Kansas, or on the City's official website address <http://www.olatheks.org/government/city-clerk/public-notices>, where a reproduction of the original ordinance will be available for a minimum of one week following this summary publication.

This summary is certified this 19th day of June, 2019.

/s/ Daniel Yoza
Daniel Yoza
Assistant City Attorney

Publish one time and return one Proof of Publication to the City Clerk and one to the City Attorney.